

PRODUCT NOTICE

Catalytic Bridge to 4-20mA Converter End of Life

Regions Affected: **GLOBAL**

Dear Customers and Colleagues

Please be advised that due to changes in legislation with regard to RoHS (Restriction of hazardous substances) directive and EMC (Electromagnetic compatibility) standard (EN 50270:2015), which will become effective on July 21st and October 19th, 2017, respectively, the Catalytic Bridge To 4-20mA Converter, with the part number 2106B1110, will be discontinued as alternatives are available.

Please refer to the following table for the withdrawal plan and replacement products. The dates shown are based on current run-rates. Should these dates change significantly due to increased or decreased run-rates, we shall issue a further communication informing of that change.

Part No	Discontinued Product	Last Order Date	Last Factory Ship Date	Replacement Products
2106B1110	Catalytic Bridge To 4-20mA Converter	April 30 th , 2017	July 14 th , 2017	Sensepoint XCD, Series 3000, and XNX Universal Transmitter which offer 4-20mA product without a requirement of a converter

For more information on the suitable alternative products, please contact sales@norrscope.com

Best regards,

Elisabeth Wasserle
EMEA Regional Product Manager Industrial Fixed
Honeywell Analytics